

## **Public Bathing Places**

### **Sampling and Laboratory Requirements Q & A**

#### How are water samples collected for bacteria analysis?

##### Beaches

- Sample must be taken at depth of approximately 30 inches **and**
- Sample must be taken at midpoint between water surface and bottom
- Each sample must be tested individually for E. coli

##### Pools

- Swimming pools, specialty pools and spas or hot tubs take water samples from area of average depth

#### When is a beach contaminated? Pool or spa?

##### Beaches

- Foreign/hazardous substance is (or may be) discharged into water
- E. coli density >235 colonies/100ml
- E. coli density >126 colonies/100ml for any 30 day geometric means

##### Pools/Spas

###### Multi-tube fermentation technique

- More than one 10ml portion of sample tests positive for coliforms
- Two consecutive samples test positive for coliforms in any 10ml portion
- Two of any 10 consecutive samples test positive for coliforms in any 10ml portion

###### Membrane filtration test

- More than one colony/50ml sample (more than 2 colonies/100ml sample)

#### How do you close a beach?

- Post signs prominently at **all** entrances
  - Signs must be at least 8"x11" in size
  - Signs must say "Beach is Closed"
  - Signs must say "Swimming Prohibited"

#### How often should water be tested?

- Sample within one week **before** opening for season
- Sample once a week **during period of maximum use**
- Department of Health (DOH) may require additional samples based on size, bather load, weather conditions, bacteriological history or other factors that may influence water quality
- Lake Erie Beaches have additional requirements
  - Three samples per beach – one taken 50 feet from each end and one in the center
  - Arithmetic mean of three samples used to determine contamination
  - No sampling when beach is closed due to high wave activity
  - Erie County Department of Health may impose additional requirements

Who can test water?

- Competent personnel at a drinking water lab registered and certified by the Pennsylvania Department of Environmental Protection

What method is used to test water?

- Testing of water shall be performed according to the procedures published in *Standard Methods for Examination of Water & Wastewater, 20<sup>th</sup> edition*, or as amended, or
- Other approved Environmental Protection Agency (EPA) method for E. coli
- The laboratory shall document the method used in completing analysis of samples and make documentation available to DOH upon request

What notification requirement is there for test results above regulatory limit?

- The lab conducting the test is required to notify the DOH within 24 hours of result availability. (Lab must report to appropriate District Office or local health department).

What should I do if sample exceeds the regulatory limit?

Beaches

- The beach shall be closed until the operator has received written authorization from DOH to reopen
- Resample immediately\*\*
- Investigate reason for exceedance and document
- Notify DOH or local health department of new result
- Receive written authorization from DOH/local health department to reopen beach

Pools

- Investigate reason for exceedance and document
- Check disinfectant level and pH (recommend pH 7.2 to 7.6, chlorine 2-4 ppm)
- Cyanuric acid not above 20 ppm, combined chlorine not above .2 ppm
- Raise chlorine to 5-10 ppm for 30 minutes
- Do not allow re-entry to pool until less than 5 ppm free chlorine, not below 1ppm
- Resample immediately after corrections are made\*\*
- Document all events and actions taken

\*\* Resampling may require special arrangements with the lab responsible for testing (e.g., holidays, weekends)

What are the record keeping requirements?

- All bacteriological testing reports shall be maintained by the permittee for two years and made available to DOH upon request